

October 02, 2023

Michael Myers  
Southern Illinois University  
Box 1028  
Edwardsville, IL 62026  
TEL: (618) 650-3477  
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE:** Southern IL University Edwardsville 1195550 Pb/Cu

**WorkOrder:** 23091022

Dear Michael Myers:

TEKLAB, INC received 20 samples on 9/15/2023 8:33:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Allison Colin  
Project Manager  
(618)344-1004 ex 43  
[acolin@teklabinc.com](mailto:acolin@teklabinc.com)

**Client:** Southern Illinois University

**Work Order:** 23091022

**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu

**Report Date:** 02-Oct-23

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Case Narrative	3
Accreditations	4
Laboratory Results	5
Receiving Check List	25
Chain of Custody	Appended



## Case Narrative

<http://www.teklabinc.com/>

**Client:** Southern Illinois University

**Work Order:** 23091022

**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu

**Report Date:** 02-Oct-23

**Cooler Receipt Temp:** 21.6 °C

---

### Locations

---

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** jhriley@teklabinc.com

---

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** EHurley@teklabinc.com

---

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415  
**Phone** (217) 698-1004  
**Fax** (217) 698-1005  
**Email** KKlostermann@teklabinc.com

---

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515  
**Phone** (630) 324-6855  
**Fax**  
**Email** arenner@teklabinc.com

---

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214  
**Phone** (913) 541-1998  
**Fax** (913) 541-1998  
**Email** jhriley@teklabinc.com

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-001**Client Sample ID:** LP2J026**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 16:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.515</b>	mg/L	100	09/25/2023 8:08	212231
Lead	NELAP	0.0010		<b>0.0029</b>	mg/L	1	09/22/2023 8:13	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-002**Client Sample ID:** LP3R045**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 16:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.749</b>	mg/L	100	09/25/2023 8:12	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 8:18	212231



## Laboratory Results

<http://www.teklabinc.com/>

Client: Southern Illinois University

Work Order: 23091022

Client Project: Southern IL University Edwardsville 1195550 Pb/Cu

Report Date: 02-Oct-23

Lab ID: 23091022-003

Client Sample ID: LP3R046

Matrix: DRINKING WATER

Collection Date: 09/14/2023 17:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.657</b>	mg/L	100	09/25/2023 8:17	212231
Lead	NELAP	0.0010		<b>0.0016</b>	mg/L	1	09/22/2023 8:22	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-004**Client Sample ID:** LP3R047**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 17:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.650</b>	mg/L	100	09/25/2023 8:21	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 8:27	212231



**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-005**Client Sample ID:** LP3R048**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 17:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.525</b>	mg/L	100	09/26/2023 11:05	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 8:45	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-006**Client Sample ID:** LP3R056**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 16:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.0010		<b>0.0663</b>	mg/L	1	09/22/2023 8:31	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 8:31	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-007**Client Sample ID:** LP3R057**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 15:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.0010		<b>0.0913</b>	mg/L	1	09/22/2023 8:36	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 8:36	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-008**Client Sample ID:** LP3R059**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 15:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.274</b>	mg/L	100	09/25/2023 8:26	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 8:40	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-009**Client Sample ID:** LP3R060**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 15:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.358</b>	mg/L	100	09/25/2023 8:30	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 9:21	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-010**Client Sample ID:** LP3R061**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 15:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.476</b>	mg/L	100	09/25/2023 8:35	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 9:26	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-011**Client Sample ID:** LP3R001**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 15:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.189</b>	mg/L	100	09/25/2023 9:11	212231
Lead	NELAP	0.0010		<b>0.0028</b>	mg/L	1	09/22/2023 9:30	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-012**Client Sample ID:** LP3R004**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 16:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.721</b>	mg/L	100	09/25/2023 9:15	212231
Lead	NELAP	0.0010		<b>0.0022</b>	mg/L	1	09/22/2023 9:35	212231



**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-013**Client Sample ID:** LP3R036**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 16:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.254</b>	mg/L	100	09/22/2023 14:20	212231
Lead	NELAP	0.0010		<b>0.0025</b>	mg/L	1	09/22/2023 9:39	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-014**Client Sample ID:** LP3R039**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 16:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.457</b>	mg/L	100	09/22/2023 14:24	212231
Lead	NELAP	0.0010		<b>0.0017</b>	mg/L	1	09/22/2023 9:44	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-015**Client Sample ID:** LP3R014**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 15:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.170</b>	mg/L	100	09/22/2023 14:47	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 9:53	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-016**Client Sample ID:** LP3R008**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 15:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.0010		<b>0.0467</b>	mg/L	1	09/22/2023 9:48	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 9:48	212231



## Laboratory Results

<http://www.teklabinc.com/>

Client: Southern Illinois University

Work Order: 23091022

Client Project: Southern IL University Edwardsville 1195550 Pb/Cu

Report Date: 02-Oct-23

Lab ID: 23091022-017

Client Sample ID: LP3R065

Matrix: DRINKING WATER

Collection Date: 09/14/2023 16:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.374</b>	mg/L	100	09/22/2023 14:29	212231
Lead	NELAP	0.0010		<b>0.0015</b>	mg/L	1	09/22/2023 10:42	212231



## Laboratory Results

<http://www.teklabinc.com/>

Client: Southern Illinois University

Work Order: 23091022

Client Project: Southern IL University Edwardsville 1195550 Pb/Cu

Report Date: 02-Oct-23

Lab ID: 23091022-018

Client Sample ID: LP3R029

Matrix: DRINKING WATER

Collection Date: 09/14/2023 15:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.149</b>	mg/L	100	09/22/2023 14:34	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 10:47	212231

**Client:** Southern Illinois University**Work Order:** 23091022**Client Project:** Southern IL University Edwardsville 1195550 Pb/Cu**Report Date:** 02-Oct-23**Lab ID:** 23091022-019**Client Sample ID:** LP3R030**Matrix:** DRINKING WATER**Collection Date:** 09/14/2023 15:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.240</b>	mg/L	100	09/22/2023 14:38	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 10:51	212231



## Laboratory Results

<http://www.teklabinc.com/>

Client: Southern Illinois University

Work Order: 23091022

Client Project: Southern IL University Edwardsville 1195550 Pb/Cu

Report Date: 02-Oct-23

Lab ID: 23091022-020

Client Sample ID: LP3R032

Matrix: DRINKING WATER

Collection Date: 09/14/2023 16:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Copper	NELAP	0.100		<b>0.185</b>	mg/L	100	09/22/2023 14:43	212231
Lead	NELAP	0.0010		<b>&lt; 0.0010</b>	mg/L	1	09/22/2023 10:56	212231





## Receiving Check List

<http://www.teklabinc.com/>

Client: Southern Illinois University

Work Order: 23091022

Client Project: Southern IL University Edwardsville 1195550 Pb/Cu

Report Date: 02-Oct-23

Carrier: Employee

Received By: MBP

Completed by:

On:

19-Sep-23

Amber Dilallo

Reviewed by:

On:

19-Sep-23

Ellie Hopkins

Pages to follow:

Chain of custody

2

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C 21.6

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice ☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - amberdilallo - 9/19/2023 3:38:26 PM

# CHAIN OF CUSTODY

pg. 1 of 2 Work order # 23-237982

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Southern Illinois University  
 Address: Box 1028  
 City / State / Zip: Edwardsville, IL 62026  
 Contact: Michael Myers Phone: (618) 650-3477  
 E-Mail: mimyers@siue.edu Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☒ NO ICE 21.6°C LTG# 3  
 Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY  
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No  
 Are these samples known to be hazardous? ☐ Yes ☐ No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED																																	
Results Requested		Billing Instructions		# and Type of Containers								Aqueous		Drinking Water		Soil		Sludge		Special Waste		Groundwater		Lead/Copper (DW)															
Lab Use Only		Sample Identification		Date/Time Sampled																																			
23091022	LP2J026	9/14/23 4:30 PM																																					
002	LP3R045	9/14/23 4:50 PM																																					
003	LP3R046	9/14/23 5:20 PM																																					
004	LP3R047	9/14/23 5:10 PM																																					
005	LP3R048	9/14/23 5:00 PM																																					
006	LP3R056	9/14/23 4:05 PM																																					
007	LP3R057	9/14/23 3:45 PM																																					
008	LP3R059	9/14/23 3:35 PM																																					
009	LP3R060	9/14/23 3:38 PM																																					
010	LP3R061	9/14/23 3:40 PM																																					

Relinquished By		Date/Time		Received By		Date/Time	
Michael Myers		9/15/23 8:33 AM		Morgan Vetter		9/15/23 0833	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 81235



pg. 2 of 2 Work order # 23-237982

Client: Southern Illinois University		Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input checked="" type="checkbox"/> NO ICE 21.6 °C LTG# 3	
Address: Box 1028		Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY	
City / State / Zip: Edwardsville, IL 62026		Lab Notes	
Contact: Michael Myers Phone: (618) 650-3477		Client Comments:	
E-Mail: mimyers@siue.edu Fax:			
Are these samples known to be involved in litigation? If yes, a surcharge will apply <input type="checkbox"/> Yes <input type="checkbox"/> No			
Are these samples known to be hazardous? <input type="checkbox"/> Yes <input type="checkbox"/> No			
Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. <input type="checkbox"/> Yes <input type="checkbox"/> No			
Project Name/Number Southern IL University Edwardsville 1195550 Pb/Cu		Sample Collector's Name	
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions	
		# and Type of Containers	
Lab Use Only		Sample Identification	
Date/Time Sampled			
23091022-011 LP3R001 9/14/23 3:50PM			
012 LP3R004 9/14/23 4:03PM			
013 LP3R036 9/14/23 4:00PM			
014 LP3R039 9/14/23 4:05PM			
015 LP3R014 9/14/23 3:59PM			
016 LP3R008 9/14/23 3:36PM			
017 LP3R065 9/14/23 4:50PM			
018 LP3R029 9/14/23 3:46PM			
019 LP3R030 9/14/23 3:52PM			
020 LP3R032 9/14/23 4:17PM			
Relinquished By		Date/Time	
9/15/23 8:33AM		Received By	
9/15/23 0833			

BottleOrder: 81235

